



Fire and Life Safety Self-Inspection Checklist.

Be prepared before your annual inspection. Below are the most common fire code violations and the corresponding International Fire Code reference number, as adopted by the City of Kirkland.

WAREHOUSES

Warehouses may include all or a portion of a business.

1. Fire protection equipment not in service (901.6 & 901.7)
2. Fire Protection equipment not serviced annually (901.6)
3. All fire alarm systems shall be monitored by an approved alarm company. (K.M.C.)
4. Fire doors shall not be blocked (703.2)
5. Obstructions in means of egress (1003.6, 1030 and 1104)
6. Lack of visible address (505.1)
7. Misuse of extension cords (605.4, 605.5.1 and 605.5)
8. Flammable liquid storage (5704.3.3.5.3)
9. Storage of oily rags. Spontaneous ignition, (304.3.1)
10. Combustible rubbish and waste material (304.3)
11. Lack of exit signs or exit sign lighting not working (1011.1)
12. No storage in front of electrical panel 36" (605.3)
13. Storage must be a minimum of 18" below sprinkler heads (315.3.1)
14. Lack of emergency vehicle access to building (503.1 & 503.4)
15. Separation and isolation of hazardous materials (5003.9.8)
16. Paint and chemical storage must be orderly (5704.3.3.5.3)
17. Painted sprinkler heads (901.6 & NFPA 13-6.2.6.2.2)
18. Battery charging areas shall be provided with a minimum 4-A:20-B:C rated fire extinguisher with 20' of battery charger. (309.4)



Kirkland Fire Marshal

123 5th Ave
Kirkland, WA 98033
Phone: (425) 587-3650